

# 2017년도 동절기 화재예방 특별점검 지적사항

NO	건물명	층별	점검일	현장사진	위반사항
1	자유관 A동	5층	2017.12.12		514호 개인 난방기구 전기히터 1EA 사용
2	자유관 A동	5층	2017.12.12		512호 개인 난방기구 온풍기 1EA 사용
3	자유관 A동	4층	2017.12.12		422호 개인 난방기구 전기히터 1EA 사용
4	자유관 A동	2층	2017.12.12		205호 UN-OSD 개인 난방기구 전기 방석 1EA 사용
5	자유관 A동	2층	2017.12.12		207호 치의예과 행정실 개인 난방기구 열풍기 1EA 사용



# 2017년도 동절기 화재예방 특별점검 지적사항

6	자유관 A동	2층	2017.12.12		206호 개인 난방기구 열풍기 1EA 사용
7	자유관 A동	2층	2017.12.12		206호 미래융합연구원 개인 난방기구 온풍기 1EA 사용
8	자유관 A동	2층	2017.12.12		206-1호 원장실 개인 난방기구 열풍기 1EA 사용
9	테크주차장	B1F	2017.12.12		자동차 실습실 개인 난방기구 열풍기 2EA 사용
10	자유관 B동	3층	2017.12.13		316호 개인 난방기구 전기히터 1EA 사용

# 2017년도 동절기 화재예방 특별점검 지적사항

11	자유관 B동	2층	2017.12.13		216호 개인 난방기구 온풍기 1EA 사용
12	자유관 B동	1층	2017.12.13		107호 경비실 개인 난방기구 열풍기 1EA 사용
13	자유관 B동	1층	2017.12.13		102호 첨단분석센터 기기운영실 개인 난방기구 전기방석 1EA 사용
14	진리관 C동	4층	2017.12.14		428호 온풍기3EA 보관
15	진리관 C동	4층	2017.12.14		423호 개별 난방기구 전기히터 1EA 사용

# 2017년도 동절기 화재예방 특별점검 지적사항

16	진리관 C동	3층	2017.12.14		<p style="text-align: center;">322호 개별 난방기구 온풍기 1EA 사용</p>
17	진리관 C동	3층	2017.12.14		<p style="text-align: center;">307호 개별 난방기구 전기히터 1EA 사용</p>
18	진리관 C동	3층	2017.12.14		<p style="text-align: center;">308호 개별 난방기구 온풍기 1EA 사용</p>
19	언더우드 기념도서관	4층	2017.12.14		<p style="text-align: center;">서비스데스크 개인 난방기구 열풍기 1EA 사용</p>
20	언더우드 기념도서관	4층	2017.12.14		<p style="text-align: center;">404호 사무실 개인 난방기구 1EA 사용</p>

# 2017년도 동절기 화재예방 특별점검 지적사항

21	Y플라자	B1F	2017.12.14		동아리방 B308호 개별 난방기구 온풍기 1EA 사용
22	Y플라자	B1F	2017.12.14		동아리방 B319호 개별 난방기구 온풍기 1EA 사용
23	Y플라자	B1F	2017.12.14		동아리방 B323호 개별 난방기구 온풍기 1EA 사용
24	Y플라자	B1F	2017.12.14		B312호 총동아리연합 개별 난방기구 온풍기 1EA 사용
25	Y플라자	B1F	2017.12.14		동아리방 B329호 개별 난방기구 온풍기 1EA 사용

# 2017년도 동절기 화재예방 특별점검 지적사항

26	Y플라자	B1F	2017.12.14		<p style="text-align: center;">동아리방 B340호 개별 난방기구 전기히터 1EA 사용</p>
27	Y플라자	B1F	2017.12.14		<p style="text-align: center;">동아리방 B340호 취사기구 전기그릴 1EA 사용</p>
28	진리관 B동	4층	2017.12.15		<p style="text-align: center;">420호 전기히터 1EA 사용</p>
29	진리관 B동	3층	2017.12.15		<p style="text-align: center;">326호 전기히터 1EA 사용</p>
30	진리관 B동	3층	2017.12.15		<p style="text-align: center;">311호 전기히터 1EA 사용</p>

# 2017년도 동절기 화재예방 특별점검 지적사항

31	진리관 B동	1층	2017.12.15		104호 관리실 열풍기 1EA 사용
32	종합관	1층	2017.12.18		휘트니스센터 안내데스크 창고 온풍기 2EA 사용
33	종합관	B1F	2017.12.18		라운샘 데크주차장 방향 사무실 온풍기 1EA 사용
34	진리관 D동	4층	2017.12.19		402호 앞 쓰레기통 부탄가스 사용
35	진리관 D동	4층	2017.12.19		405호 내부 개별난방기구 온풍기 1EA 사용

# 2017년도 동절기 화재예방 특별점검 지적사항

36	진리관 D동	4층	2017.12.19		414호 개별난방기구 온풍기 1EA 사용
37	진리관 D동	4층	2017.12.19		422-2호 내부 개별난방기구 온풍기 1EA 사용
38	진리관 D동	2층	2017.12.19		208호 개별 난방기구 선풍기형 히터, 전기히터 사용
39	진리관 D동	2층	2017.12.19		208호 취사도구 전기오븐 사용
40	진리관 D동	2층	2017.12.19		214호 개별 난방기구 온풍기1EA 사용

# 2017년도 동절기 화재예방 특별점검 지적사항

41	진리관 D동	1층	2017.12.19		<p>103호 학생휴게실 개별 난방기구 전기장판 2EA, 온풍기 1EA 사용</p>
42	진리관 D동	1층	2017.12.19		<p>105호 약학과 개별 난방기구 온풍기 1EA 사용</p>
43	송도 2학사	1층	2017.12.20		<p>D동 320호 세미나실(중) 개별 난방기구 전기히터 1EA 사용</p>